

Facility Summary in Glacier County in the City of Babb

Location: THRONSONS STORE
US Hwy 89
Babb, MT 59411 Glacier

System Facility ID:18-03871

Facility Code: 21949
Last Inspected On: 04/06/2020
Operating Permit Renewal Date: 09/03/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Thronsons Store **4067325530**

Operator Contact: Michael Thronson **4067325530**

Owner/Operator: Thronsons Store

Michael Thronson, UST Class A Operator
Michael Thronson, UST Class B Global Operator

Tank Code	07	Tank Age	33	Tank Installed Date	12/31/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4401	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/26/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/26/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7000	ATG Test Date		Line Tightness Test Date	05/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/				
Tank Code	08	Tank Age	33	Tank Installed Date	12/31/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4402	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/26/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/26/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	05/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/				
Tank Code	06	Tank Age	33	Tank Installed Date	12/31/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4403	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	05/26/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/26/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	05/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/				

Facility Summary in Glacier County in the City of Browning

Location: COOP'S CORNER CONOCO
330 W Central Ave
Browning, MT 59417 Glacier

System Facility ID:18-05813

Facility Code: 21980
Last Inspected On: 03/09/2021
Operating Permit Renewal Date: 03/13/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glacier Park 66 Inc **4063382575**

Operator Contact: Michael Sherwood;Randy Livingston;Troy Wilson **4063382575**

Owner/Operator: Glacier Park 66 Inc

- Michael Sherwood, UST Class A Operator
- Michael Sherwood, UST Class B Operator
- Randy Livingston, UST Class A Operator
- Randy Livingston, UST Class B Operator
- Troy Wilson, UST Class A Operator
- Troy Wilson, UST Class B Global Operator

Tank Code	04	Tank Age	25	Tank Installed Date	01/03/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4441	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/10/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	12/10/2008	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	25	Tank Installed Date	01/03/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	4442	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/10/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/25/2017	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	25	Tank Installed Date	01/03/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4443	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/10/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/25/2017	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Glacier County in the City of Browning

Location: GLACIER FAMILY FOODS
601 SE Boundary St
Browning, MT 59417 Glacier

System Facility ID:60-15286

Facility Code: 30993
Last Inspected On: 07/26/2022
Operating Permit Renewal Date: 10/14/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Siyeh Development Corporation

Operator Contact: Dori Goss;Mark Magee;Tahnee Armstrong

4063385669;4063387283

Owner/Operator: Siyeh Development Corporation

Dori Goss, UST Class A Operator
Dori Goss, UST Class B Operator
Mark Magee, UST Class A Operator
Mark Magee, UST Class B Operator
Tahnee Armstrong, UST Class A Operator
Tahnee Armstrong, UST Class B Operator

Tank Code	01	Tank Age	7	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5673	Spill Test Date	03/25/2022	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/27/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/26/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/14/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	02	Tank Age	7	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5674	Spill Test Date	09/14/2021	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/27/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/26/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/14/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	03	Tank Age	7	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5675	Spill Test Date	09/14/2021	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/27/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	07/26/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	09/14/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	04	Tank Age	7	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5676	Spill Test Date	09/14/2021	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/27/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	07/26/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/14/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				

Facility Summary in Glacier County in the City of Browning

Location: GLACIER WAY CONVENIENCE STORE
200 MT Hwy 464
Browning, MT 59417 Glacier

System Facility ID:18-13768

Facility Code: 22049
Last Inspected On: 11/23/2020
Operating Permit Renewal Date: 12/20/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Pat Schildt

4063384464

Operator Contact: Charles Lafley;Harold Schildt;Pardeep Kumar;Stacey Keller

4063384464;4063387568;4084499333;7755602318

Owner/Operator: Pat Schildt

- Charles Lafley, UST Class A Operator
- Charles Lafley, UST Class B Global Operator
- Harold Schildt, UST Class A Operator
- Harold Schildt, UST Class B Global Operator
- Pardeep Kumar, UST Class A Operator
- Pardeep Kumar, UST Class B Operator
- Paul Johnson, UST Class B Operator
- Stacey Keller, UST Class A Operator
- Stacey Keller, UST Class B Global Operator

Tank Code	01	Tank Age	26	Tank Installed Date	09/25/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3425	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/22/2021	Sump Tightness Test Date	04/20/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/09/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	02/22/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC; Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	02	Tank Age	26	Tank Installed Date	09/25/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3426	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/22/2021	Sump Tightness Test Date	04/20/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/09/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	02/22/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC; Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	03	Tank Age	26	Tank Installed Date	09/25/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3427	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/22/2021	Sump Tightness Test Date	04/20/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/09/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	02/22/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Vaporless Manufacturing/Vaporless 99LD-2000			
--	--	---------------------------	--	--	-----------------	---------------------------------------------------------------------------------------	--	--	--

Facility Summary in Glacier County in the City of Browning

Location: PARK CAFE AND GROCERY
3147 US Hwy 89 W
Browning, MT 59417-9701 Glacier

System Facility ID:18-06436

Facility Code: 21989
Last Inspected On: 04/06/2020
Operating Permit Renewal Date: 05/30/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hilton Family Corporation;Neil Miller **4067324482;4068925589**

Operator Contact: Keith Hilton **4062501193**

Owner/Operator: Hilton Family Corporation

Owner/Operator: Neil Miller

Keith Hilton, UST Class A Operator
Keith Hilton, UST Class B Operator

Tank Code	05	Tank Age	31	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1380	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/10/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/10/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	06	Tank Age	31	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1381	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	05/10/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/10/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC; Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	07	Tank Age	31	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1382	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/10/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	05/10/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC; Vaporless Manufacturing/Vaporless 99LD-2000				

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 MAINTENANCE COMPLEX
105 E Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-03868

Facility Code: 21947
Last Inspected On: 03/02/2022
Operating Permit Renewal Date: 03/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 9 Browning

Operator Contact: Wayne Bullcalf

Owner/Operator: School Dist 9 Browning

Wayne Bullcalf, UST Class A Operator
Wayne Bullcalf, UST Class B Operator

Tank Code	02	Tank Age	36	Tank Installed Date	11/29/1986	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4130	Spill Test Date	04/05/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	03/02/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/05/2022			ATG Type	Gilbarco/TLS-350				
Tank Code	03	Tank Age	33	Tank Installed Date	11/28/1989	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4131	Spill Test Date	04/05/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	03/02/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/05/2022			ATG Type	Gilbarco/TLS-350				

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 TRANSPORTATION DEPT
829 SW Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-12747

Facility Code: 22038
Last Inspected On: 03/02/2022
Operating Permit Renewal Date: 03/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 9 Browning

Operator Contact:

Owner/Operator: School Dist 9 Browning

Wayne Bullcalf, UST Class B Global Operator

Tank Code	01	Tank Age	30	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1898	Spill Test Date	03/02/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLLD Test Date	03/02/2022	Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/02/2022	Line Tightness Test Date	03/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/22/2022			ATG Type	Gilbarco/TLS-350				
Tank Code	02	Tank Age	30	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1899	Spill Test Date	03/23/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/02/2022	Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/02/2022	Line Tightness Test Date	03/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/22/2022			ATG Type	Gilbarco/TLS-350				
Tank Code	03	Tank Age	30	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1900	Spill Test Date	03/02/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/24/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	03/02/2022	Line Tightness Test Date	09/08/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/22/2022			ATG Type	Gilbarco/TLS-350				

Facility Summary in Glacier County in the City of Browning

Location: TOWN PUMP INC BROWNING 2
304 SE Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-08677

Facility Code: 22011
Last Inspected On: 12/16/2021
Operating Permit Renewal Date: 04/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town Pump Inc Browning 2

Operator Contact: Trent Biggers

Owner/Operator: Town Pump Inc Browning 2

Trent Biggers, UST Class A Operator

Tank Code	09	Tank Age	27	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2463	Spill Test Date	01/12/2022	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/26/2022	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/26/2022	Line Tightness Test Date	12/01/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	27	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2465	Spill Test Date	01/12/2022	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/26/2022	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/26/2022	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	27	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2466	Spill Test Date	07/14/2021	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/26/2022	Tank/Piping CP Test Date	12/04/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/26/2022	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	27	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	2467	Spill Test Date	01/12/2022	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/26/2022	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/26/2022	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	01/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	14	Tank Age	19	Tank Installed Date	08/14/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4859	Spill Test Date	07/14/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/26/2022	Tank/Piping CP Test Date	12/04/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/26/2022	Line Tightness Test Date	12/01/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	15	Tank Age	19	Tank Installed Date	08/14/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4860	Spill Test Date	01/12/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/26/2022	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/26/2022	Line Tightness Test Date	12/01/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	27	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4888	Spill Test Date	01/12/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	07/26/2022	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/26/2022	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of Cut Bank

Location: BEN TAYLOR INC - CUT BANK BULK PLANT
201 BN Industrial Site
Cut Bank, MT 59427-2936 Glacier

System Facility ID:18-04137

Facility Code: 21958
Last Inspected On: 08/02/2022
Operating Permit Renewal Date: 11/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ben Taylor Inc

Operator Contact: Scott Curry;Shannon Gabbard

4068732812

Owner/Operator: Ben Taylor Inc

Scott Curry, UST Class A Operator
Shannon Gabbard, UST Class A Operator
Shannon Gabbard, UST Class B Operator

Tank Code	S16	Tank Age	22	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4241	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/02/2022	Sump Tightness Test Date	08/02/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	34000	ATG Test Date		Line Tightness Test Date	08/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	S17	Tank Age	22	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4242	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes

Tank Status	Currently in Use	MLLD Test Date	08/02/2022	Sump Tightness Test Date	08/02/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	11700	ATG Test Date		Line Tightness Test Date	08/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	S18	Tank Age	22	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4243	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/02/2022	Sump Tightness Test Date	08/02/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12500	ATG Test Date		Line Tightness Test Date	08/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	S19	Tank Age	22	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4244	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/02/2022	Sump Tightness Test Date	08/02/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	34000	ATG Test Date		Line Tightness Test Date	08/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	S20	Tank Age	22	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4245	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/02/2022	Sump Tightness Test Date	08/02/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	

Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12500	ATG Test Date		Line Tightness Test Date	08/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000				
Tank Code	S21	Tank Age	22	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4246	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/02/2022	Sump Tightness Test Date	08/02/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	11700	ATG Test Date		Line Tightness Test Date	08/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000				

Facility Summary in Glacier County in the City of Cut Bank

Location: BTI 813 E RAILROAD CARDLOCK
813 E Railroad St
Cut Bank, MT 59427 Glacier

System Facility ID:56-13775

Facility Code: 30464
Last Inspected On: 02/27/2020
Operating Permit Renewal Date: 07/30/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ben Taylor Inc

Operator Contact: Scott Curry;Steve Nelson

4068734612

Owner/Operator: Ben Taylor Inc

Joseph Pehan, UST Class B Operator
Justin Aikins, UST Class B Operator
Scott Curry, UST Class A Operator
Steve Nelson, UST Class A Operator
Steve Nelson, UST Class B Operator

Tank Code	S1	Tank Age	25	Tank Installed Date	10/31/1997	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
-----------	----	----------	----	---------------------	------------	---------------	------------	-----------------	------------------	----------------	--

Tag Number	1928	Spill Test Date		Piping Installed Date	01/03/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS-LLD				
Tank Code	S2	Tank Age	25	Tank Installed Date	10/31/1997	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1929	Spill Test Date		Piping Installed Date	01/03/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS-LLD				
Tank Code	03	Tank Age	10	Tank Installed Date	03/01/2012	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5494	Spill Test Date		Piping Installed Date	03/01/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	11800	ATG Test Date		Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS-LLD				

Facility Summary in Glacier County in the City of Cut Bank

Location: CUT BANK MUNICIPAL AIRPORT
2705 Valier Hwy
Cut Bank, MT 59427 Glacier

System Facility ID:18-00137

Facility Code: 21903
Last Inspected On: 09/28/2022
Operating Permit Renewal Date: 01/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cut Bank Airport Authority

4068738683

Operator Contact: Ronald Hermanet;Roy Nollkamper

4068738683

Owner/Operator: Cut Bank Airport Authority

Ronald Hermanet, UST Class A Operator
 Roy Nollkamper, UST Class A Operator
 Roy Nollkamper, UST Class B Operator
 Tom Redfield, UST Class B Global Operator

Tank Code	08	Tank Age	25	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	793	Spill Test Date	07/12/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2022	Sump Tightness Test Date	09/28/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/06/2022	Line Tightness Test Date	04/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/25/2022			ATG Type	Gilbarco-Veeder Root/EMC Basic;Veeder Root/Red Jacket FXIV				
Tank Code	09	Tank Age	25	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	794	Spill Test Date	07/12/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2022	Sump Tightness Test Date	09/28/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/06/2022	Line Tightness Test Date	04/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/25/2022			ATG Type	Gilbarco-Veeder Root/EMC Basic;Veeder Root/Red Jacket FXIV				

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP INC CUT BANK 2
 510 W Main St
 Cut Bank, MT 59427-2808 Glacier

System Facility ID:18-03417

Facility Code: 21942
 Last Inspected On: 07/15/2021
 Operating Permit Renewal Date: 10/04/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cut Bank 2 Town Pump LLC

4064976700

Operator Contact: Trent Biggers

Owner/Operator: Cut Bank 2 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	29	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2459	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/27/2022	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	29	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	2460	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/27/2022	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	29	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	2461	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/27/2022	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/24/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	29	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2462	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/27/2022	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	22	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4185	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/27/2022	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	22	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4186	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	5000	ATG Test Date	07/27/2022	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP OF CUT BANK #3
1119 E Main St
Cut Bank, MT 59427 Glacier

System Facility ID:60-15144

Facility Code: 30888
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 12/11/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cut Bank 1 Town Pump LLC

4064976700

Operator Contact: Trent Biggers

Owner/Operator: Cut Bank 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	12	Tank Installed Date	07/03/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5227	Spill Test Date	07/24/2021	Piping Installed Date	07/03/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	12	Tank Installed Date	07/03/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5228	Spill Test Date	07/24/2021	Piping Installed Date	07/03/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	12000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	12	Tank Installed Date	07/03/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5229	Spill Test Date	07/24/2021	Piping Installed Date	07/03/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of East Glacier Park

Location: BEAR TRACK TRAVEL CENTER
20958 US Hwy 2
East Glacier Park, MT 59434 Glacier

System Facility ID:56-13933

Facility Code: 30603
Last Inspected On: 11/23/2021
Operating Permit Renewal Date: 11/23/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Blackfeet Tribe

Operator Contact: Mark Magee;Tahnee Armstrong;Siyeh Development Corporation;Thomas Bearchild

4063385669

Owner/Operator: Blackfeet Tribe

Mark Magee, UST Class A Operator
Mark Magee, UST Class B Operator
Tahnee Armstrong, UST Class A Operator
Tahnee Armstrong, UST Class B Operator
Thomas Bearchild, UST Class A Operator
Thomas Bearchild, UST Class B Operator

Tank Code	S1	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4068	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/16/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/23/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/23/2021			ATG Type	Franklin Fueling Systems/TS-LLD				
Tank Code	S2	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4069	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/23/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/23/2021			ATG Type	Franklin Fueling Systems/TS-LLD				
Tank Code	S3	Tank Age	15	Tank Installed Date	09/14/2007	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5126	Spill Test Date		Piping Installed Date	04/23/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/23/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/23/2021			ATG Type	Franklin Fueling Systems/TS-LLD				

Facility Summary in Glacier County in the City of East Glacier Park

Location: SEARS MOTEL and GIFT SHOP
1023 Hwy 49 N
East Glacier Park, MT 59434 Glacier

System Facility ID:18-03870

Facility Code: 21948
Last Inspected On: 02/05/2021
Operating Permit Renewal Date: 02/05/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Judy Jones **2396940279**

Operator Contact: Judy Jones **2396940279**

Owner/Operator: Judy Jones

Judy Jones, UST Class A Operator
Judy Jones, UST Class B Operator

Tank Code	03	Tank Age	32	Tank Installed Date	09/28/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1453	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	32	Tank Installed Date	09/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1454	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Glacier County in the City of Saint Mary

Location: SAINT MARY RANGER STATION
73 Hudson Bay Rd
Saint Mary, MT 59411 Glacier

System Facility ID:18-02745

Facility Code: 21939
Last Inspected On: 04/25/2022
Operating Permit Renewal Date: 04/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Browning

4067327724

Operator Contact: Jeff Wysong;Mark Hickcox;Patrick Glynn

4067327721;4067327724;4068887967

Owner/Operator: National Park Service Browning

Jeff Wysong, UST Class A Operator
Mark Hickcox, UST Class A Operator
Mark Hickcox, UST Class B Global Operator
Patrick Glynn, UST Class A Operator
Patrick Glynn, UST Class B Global Operator

Tank Code	04	Tank Age	35	Tank Installed Date	07/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1221	Spill Test Date	03/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/20/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/31/2022	Tank/Piping CP Test Date	03/31/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/31/2022	Line Tightness Test Date	11/03/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	7	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5620	Spill Test Date	03/31/2022	Piping Installed Date	10/28/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/31/2022	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No

Capacity	10000	ATG Test Date	03/31/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Glacier County in the City of Saint Mary

Location: ST MARY LODGE
3 Going To The Sun Rd
Saint Mary, MT 59411 Glacier

System Facility ID:18-01907

Facility Code: 21924
Last Inspected On: 10/08/2020
Operating Permit Renewal Date: 10/20/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glacier Park Inc;Sally Welder **4068926708**

Operator Contact: Jon Noe;Lisa Wyrick **4062265675;4067324431**

Owner/Operator: Glacier Park Inc

Owner/Operator: Sally Black Welder

Bob Hines, UST Class B Operator
Jon Noe, UST Class A Operator
Lisa Wyrick, UST Class A Operator
Lisa Wyrick, UST Class B Operator

Tank Code	01	Tank Age	32	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	451	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/21/2022	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/07/2022	Line Tightness Test Date	10/17/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	32	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	452	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/21/2022	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/07/2022	Line Tightness Test Date	10/17/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	32	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	453	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/21/2022	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7000	ATG Test Date	04/07/2022	Line Tightness Test Date	10/17/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	32	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	454	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/21/2022	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	04/07/2022	Line Tightness Test Date	10/17/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				